



# Compliance Statement

## Screened Category 6<sub>A</sub> ISO/IEC, EN & ANSI/TIA Communication Cable

**YFC-BonEagle Identification P/N YLC-APPAH04-CR-LLLcc**

Category 6<sub>A</sub>, Individual Foil and without Overall Braid Screened  
100 Ω, 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Cable

**YFC-BonEagle Electric Co., Ltd.**  
**No. 12-9, Lane 130, Sec. 2, Chungshan E. Road**  
**Hsinwu, Taoyuan, Taiwan, R.O.C.**

*Compliance Statement No. 115904*

*This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6<sub>A</sub> performance requirements of edition 2.2 of ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2011, ANSI/TIA Generic Cabling Standard 568-C.2, 2<sup>nd</sup> edition IEC Cable Standard 61156-5, incl. amendment 1 and requirements of CENELEC Cable Standard EN 50288-10-1:2012. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1, and IEC 60754-2. The cable has EMC Performance Rating 8. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.*

Hoersholm, 7<sup>th</sup> January 2015

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen  
Test Responsible

Hoersholm, 7<sup>th</sup> January 2015

A handwritten signature in blue ink, appearing to read "Poul Villien".

Poul Villien  
Coordinating Manager